

IRRIGATION AUTHORITY

Supply, Installation, Testing and Commissioning of a Surface Centrifugal Pumpset complete with an Auto-Transformer type Control Panel at Palmar Pumping Station

Procurement Reference No: OAB/OMD/PALMARPUMP/10/24

Minutes of pre-bid site meeting/visit scheduled on Thursday 18 April 2024 on site at Palmar Pumping Station.

1.0 Introduction

No Bidder was present.

However, Bidders are informed that they can visit the site upon prior appointment and arrangement with the Irrigation Authority.

Bidders are reminded of the following points as highlighted hereunder.

2.0 Scope of works and Specifications

The Bidders are requested to go through the bidding document which is available on-line on the website of the Irrigation Authority at <http://ia.govmu.org> and to submit their proposals as per the scope of works and specifications and to prepare their Bid in accordance with the Bill of Quantity.

However, in view of the actual space constraints and the existing pipe arrangement, Bidders are hereby notified that the pump type which is most suitable to be supplied and installed is an **end suction type** having a single-stage impeller with a suction inlet located at one end and a discharge outlet perpendicular to the pump shaft.

The pump characteristics and other information pertaining to the auto-transformer starter panel shall remain unchanged.

A corrigendum shall be issued in that regard.

3.0 Layout of the Pumpset

The Bidders are informed that the proposed layout is as given in the tender drawing at OAB/OMD/PALMARPUMP/10/24/02, which is most appropriate for an end suction type pumpset.

Pre-bid minutes prepared and submitted by Mr B. SEEWOODHARRY (Operation and Maintenance Engineer)

April 2024